

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on March 28)**

Water Level of the accumulated water (at 16:00 on March 28)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,339 mm (15 mm decrease since 7:00 on March 28)	O.P.+ 2,772 mm (2 mm decrease since 7:00 on March 28)	—
	Water level of Turbine Building	O.P.+ 2,741 mm (No change since 7:00 on March 28)	O.P.+ 3,309 mm (13 mm decrease since 7:00 on March 28)	O.P.+ 2,650 mm (21 mm increase since 7:00 on March 28)	O.P.+ 2,670 mm (7 mm decrease since 7:00 on March 28)
	Water level of Reactor Building	O.P.+ 4,325 mm (15 mm increase since 7:00 on March 28)	O.P.+ 3,612 mm (6 mm increase since 7:00 on March 28)	O.P.+ 2,850 mm (15 mm increase since 7:00 on March 28)	O.P.+ 2,696 mm (8 mm decrease since 7:00 on March 28)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,218 mm (Increase from initial level:5,435 mm, 1 mm increase since 7:00 on March 28) O.P.+ 2,906 mm (Increase from initial level:3,632 mm, 53 mm decrease since 7:00 on March 28) O.P.+ 4,310 mm (Water level from floor:514 mm, 1 mm increase since 7:00 on March 28)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:22 on March 28)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:16 on March 22)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 15:00 on March 27 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.