

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on March 29)**

Water Level of the accumulated water (at 7:00 on March 29)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,294 mm (45 mm decrease since 16:00 on March 28)	O.P.+ 2,784 mm (12 mm increase since 16:00 on March 28)	—
	Water level of Turbine Building	O.P.+ 2,742 mm (1 mm increase since 16:00 on March 28)	O.P.+ 3,270 mm (39 mm decrease since 16:00 on March 28)	O.P.+ 2,675 mm (25 mm increase since 16:00 on March 28)	O.P.+ 2,669 mm (1 mm decrease since 16:00 on March 28)
	Water level of Reactor Building	O.P.+ 4,336 mm (11 mm increase since 16:00 on March 28)	O.P.+ 3,581 mm (31 mm decrease since 16:00 on March 28)	O.P.+ 2,879 mm (29 mm increase since 16:00 on March 28)	O.P.+ 2,695 mm (1 mm decrease since 16:00 on March 28)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,222 mm (Increase from initial level:5,439 mm, 4 mm increase since 16:00 on March 28) O.P.+ 2,862 mm (Increase from initial level:3,588 mm, 44 mm decrease since 16:00 on March 28) O.P.+ 4,310 mm (Water level from floor:514 mm, No change since 16:00 on March 28)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:22 on March 28)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:16 on March 22)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 15:00 on March 27   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.