

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on March 29)**

Water Level of the accumulated water (at 16:00 on March 29)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,268 mm (26 mm decrease since 7:00 on March 29)	O.P.+ 2,792 mm (8 mm increase since 7:00 on March 29)	—
	Water level of Turbine Building	O.P.+ 2,742 mm (No change since 7:00 on March 29)	O.P.+ 3,249 mm (21 mm decrease since 7:00 on March 29)	O.P.+ 2,684 mm (9 mm increase since 7:00 on March 29)	O.P.+ 2,674 mm (5 mm increase since 7:00 on March 29)
	Water level of Reactor Building	O.P.+ 4,336 mm (No change since 7:00 on March 29)	O.P.+ 3,558 mm (23 mm decrease since 7:00 on March 29)	O.P.+ 2,888 mm (9 mm increase since 7:00 on March 29)	O.P.+ 2,698 mm (3 mm increase since 7:00 on March 29)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,223 mm (Increase from initial level:5,440 mm, 1 mm increase since 7:00 on March 29) O.P.+ 2,838 mm (Increase from initial level:3,564 mm, 24 mm decrease since 7:00 on March 29) O.P.+ 4,310 mm (Water level from floor:514 mm, No change since 7:00 on March 29)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:22 on March 28)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:16 on March 22)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 15:00 on March 27   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.