

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on April 1)**

Water Level of the accumulated water (at 7:00 on April 1)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,101 mm (37 mm decrease since 16:00 on March 31)	O.P.+ 2,835 mm (9 mm increase since 16:00 on March 31)	—
	Water level of Turbine Building	O.P.+ 2,744 mm (1 mm increase since 16:00 on March 31)	O.P.+ 3,105 mm (32 mm decrease since 16:00 on March 31)	O.P.+ 2,727 mm (8 mm increase since 16:00 on March 31)	O.P.+ 2,713 mm (9 mm increase since 16:00 on March 31)
	Water level of Reactor Building	O.P.+ 4,266 mm (25 mm decrease since 16:00 on March 31)	O.P.+ 3,416 mm (34 mm decrease since 16:00 on March 31)	O.P.+ 2,937 mm (11 mm increase since 16:00 on March 31)	O.P.+ 2,730 mm (8 mm increase since 16:00 on March 31)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,232 mm (Increase from initial level:5,449 mm, 2 mm increase since 16:00 on March 31) O.P.+ 2,699 mm (Increase from initial level:3,425 mm, 31 mm decrease since 16:00 on March 31) O.P.+ 4,312 mm (Water level from floor:516 mm, 1 mm increase since 16:00 on March 31)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:22 on March 28)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:16 on March 22)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 15:00 on March 27 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.