

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on April 1)**

Water Level of the accumulated water (at 16:00 on April 1)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,118 mm (17 mm increase since 7:00 on April 1)	O.P.+ 2,825 mm (10 mm decrease since 7:00 on April 1)	—
	Water level of Turbine Building	O.P.+ 2,743 mm (1 mm decrease since 7:00 on April 1)	O.P.+ 3,119 mm (14 mm increase since 7:00 on April 1)	O.P.+ 2,711 mm (16 mm decrease since 7:00 on April 1)	O.P.+ 2,715 mm (2 mm increase since 7:00 on April 1)
	Water level of Reactor Building	O.P.+ 4,251 mm (15 mm decrease since 7:00 on April 1)	O.P.+ 3,411 mm (5 mm decrease since 7:00 on April 1)	O.P.+ 2,923 mm (14 mm decrease since 7:00 on April 1)	O.P.+ 2,733 mm (3 mm increase since 7:00 on April 1)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,233 mm (Increase from initial level:5,450 mm, 1 mm increase since 7:00 on April 1) O.P.+ 2,682 mm (Increase from initial level:3,408 mm, 17 mm decrease since 7:00 on April 1) O.P.+ 4,311 mm (Water level from floor:515 mm, 1 mm decrease since 7:00 on April 1)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Transfer Completed (From 10:22 on March 28 to 9:48 on April 1)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:16 on March 22)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 15:00 on March 27 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.