

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on April 2)**

Water Level of the accumulated water (at 7:00 on April 2)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,167 mm (49 mm increase since 16:00 on April 1)	O.P.+ 2,811 mm (14 mm decrease since 16:00 on April 1)	—
	Water level of Turbine Building	O.P.+ 2,744 mm (1 mm increase since 16:00 on April 1)	O.P.+ 3,160 mm (41 mm increase since 16:00 on April 1)	O.P.+ 2,677 mm (34 mm decrease since 16:00 on April 1)	O.P.+ 2,707 mm (8 mm decrease since 16:00 on April 1)
	Water level of Reactor Building	O.P.+ 4,235 mm (16 mm decrease since 16:00 on April 1)	O.P.+ 3,447 mm (36 mm increase since 16:00 on April 1)	O.P.+ 2,889 mm (34 mm decrease since 16:00 on April 1)	O.P.+ 2,727 mm (6 mm decrease since 16:00 on April 1)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,236 mm (Increase from initial level:5,453 mm, 3 mm increase since 16:00 on April 1) O.P.+ 2,654 mm (Increase from initial level:3,380 mm, 28 mm decrease since 16:00 on April 1) O.P.+ 4,312 mm (Water level from floor:516 mm, 1 mm increase since 16:00 on April 1)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:16 on March 22)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 15:00 on March 27   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.