

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on April 4)**

Water Level of the accumulated water (at 7:00 on April 4)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,310 mm (46 mm increase since 16:00 on April 4)	O.P.+ 2,781 mm (9 mm decrease since 16:00 on April 4)	—
	Water level of Turbine Building	O.P.+ 2,748 mm (2 mm increase since 16:00 on April 4)	O.P.+ 3,285 mm (41 mm increase since 16:00 on April 4)	O.P.+ 2,639 mm (11 mm decrease since 16:00 on April 4)	O.P.+ 2,675 mm (11 mm decrease since 16:00 on April 4)
	Water level of Reactor Building	O.P.+ 4,431 mm (95 mm increase since 16:00 on April 4)	O.P.+ 3,571 mm (3 mm increase since 16:00 on April 4)	O.P.+ 2,848 mm (20 mm decrease since 16:00 on April 4)	O.P.+ 2,702 mm (12 mm decrease since 16:00 on April 4)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,244 mm (Increase from initial level:5,461 mm, 2 mm increase since 16:00 on April 4) O.P.+ 2,484 mm (Increase from initial level:3,210 mm, 63 mm decrease since 16:00 on April 4) O.P.+ 4,314 mm (Water level from floor:518 mm, 1 mm increase since 16:00 on April 4)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:16 on March 22)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:23 on April 4 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- At 8:23 AM on April 4, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning. We would like to correct the previous update as follows. We apologize for the mistake. At around 5:23 AM on April 4, 2013, the multi-nuclide removal equipment (ALPS) for which hot testing using waste liquid treated by the contaminated water treatment facility was being performed has been suspended due to incorrect operation.Since no abnormality was found as a result of site investigation, the treatment of water remaining in the system was restarted at 6:33 AM on the same day. No problem has been found with its operation after restarting the treatment of the remaining water.				

For quick publication of the data of water level, values are provided as reference values.