

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on April 5)**

Water Level of the accumulated water (at 7:00 on April 5)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,371 mm (37 mm increase since 16:00 on April 4)	O.P.+ 2,759 mm (13 mm decrease since 16:00 on April 4)	—
	Water level of Turbine Building	O.P.+ 2,750 mm (1 mm increase since 16:00 on April 4)	O.P.+ 3,338 mm (32 mm increase since 16:00 on April 4)	O.P.+ 2,617 mm (13 mm decrease since 16:00 on April 4)	O.P.+ 2,656 mm (13 mm decrease since 16:00 on April 4)
	Water level of Reactor Building	O.P.+ 4,487 mm (25 mm increase since 16:00 on April 4)	O.P.+ 3,620 mm (30 mm increase since 16:00 on April 4)	O.P.+ 2,822 mm (16 mm decrease since 16:00 on April 4)	O.P.+ 2,683 mm (12 mm decrease since 16:00 on April 4)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,248 mm (Increase from initial level:5,465 mm, 3 mm increase since 16:00 on April 4) O.P.+ 2,472 mm (Increase from initial level:3,198 mm, 94 mm decrease since 16:00 on April 4) O.P.+ 4,316 mm (Water level from floor:520 mm, 2 mm increase since 16:00 on April 4)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:16 on March 22)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:23 on April 4 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- At around 5:23 AM on April 4, 2013, the multi-nuclide removal equipment (ALPS) for which hot testing using waste liquid treated by the contaminated water treatment facility was being performed has been suspended due to incorrect operation.Since no abnormality was found as a result of site investigation, the treatment of water remaining in the system was restarted at 6:33 AM on the same day. No problem has been found with its operation after restarting the treatment of the remaining water. The treatment of water remaining in the system was completed at 6:54 PM on the same day.				

For quick publication of the data of water level, values are provided as reference values.