

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on April 5)**

|   |  |  |  |  |   |
|---|--|--|--|--|---|
| Water Level of the accumulated water<br>(at 16:00 on April 5) |  | Unit 1   | Unit 2   | Unit 3   | Unit 4  |
|   | Water level of Vertical Shaft  | Unmeasurable due to drawdown of water level<br>(Less than O.P.+ 850 mm)  | O.P.+ 3,364 mm<br>(7 mm decrease since 7:00 on April 5)  | O.P.+ 2,752 mm<br>(7 mm decrease since 7:00 on April 5)  | —   |
|   | Water level of Turbine Building  | O.P.+ 2,749 mm<br>(1 mm decrease since 7:00 on April 5)  | O.P.+ 3,332 mm<br>(6 mm decrease since 7:00 on April 5)  | O.P.+ 2,610 mm<br>(7 mm decrease since 7:00 on April 5)  | O.P.+ 2,648 mm<br>(8 mm decrease since 7:00 on April 5) |
|   | Water level of Reactor Building  | O.P.+ 4,492 mm<br>(5 mm increase since 7:00 on April 5)  | O.P.+ 3,631 mm<br>(11 mm increase since 7:00 on April 5)   | O.P.+ 2,815 mm<br>(7 mm decrease since 7:00 on April 5)  | O.P.+ 2,677 mm<br>(6 mm decrease since 7:00 on April 5) |
|   | Water level of each building in the Centralized Radiation Waste Treatment Facility | Process Main Building<br>High Temperature Incinerator Building<br>On-site Bunker Building  | O.P.+ 4,249 mm (Increase from initial level:5,466 mm, 1 mm increase since 7:00 on April 5)<br>O.P.+ 2,524 mm (Increase from initial level:3,250 mm, 52 mm increase since 7:00 on April 5)<br>O.P.+ 4,316 mm (Water level from floor:520 mm, No change since 7:00 on April 5) |  |   |
| Situation of transfer of the accumulated water                |  | Unit 1   | Unit 2   | Unit 3   | Unit 4  |
|   |  | —  | Basement of Unit 2 Turbine Building<br>→Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building)<br>Currently being transferred<br>(Since 10:29 on April 5)  | Basement of Unit 3 Turbine Building<br>→Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building)<br>Currently being transferred<br>(Since 14:16 on March 22) | —   |
|   |  | Unit 5 and 6   |  |  |   |
|   |  |  |  |  |   |
| Operation condition of water treatment facility               |  | Cesium Adsorption Apparatus: Since 9:28 on March 21   Suspended<br>2nd Cesium Adsorption Apparatus (Sarry): Since 12:23 on April 4   In operation<br>Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance<br>Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance |  |  |   |
| Notes   |  |  |  |  |   |

For quick publication of the data of water level, values are provided as reference values.