

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on April 8)**

Water Level of the accumulated water (at 7:00 on April 8)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,260 mm (24 mm decrease since 16:00 on April 7)	O.P.+ 2,794 mm (17 mm increase since 16:00 on April 7)	—
	Water level of Turbine Building	O.P.+ 2,765 mm (9 mm increase since 16:00 on April 7)	O.P.+ 3,242 mm (21 mm decrease since 16:00 on April 7)	O.P.+ 2,682 mm (17 mm increase since 16:00 on April 7)	O.P.+ 2,664 mm (15 mm increase since 16:00 on April 7)
	Water level of Reactor Building	O.P.+ 4,645 mm (45 mm increase since 16:00 on April 7)	O.P.+ 3,547 mm (39 mm decrease since 16:00 on April 7)	O.P.+ 2,892 mm (17 mm increase since 16:00 on April 7)	O.P.+ 2,683 mm (10 mm increase since 16:00 on April 7)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,262 mm (Increase from initial level:5,479 mm, 3 mm increase since 16:00 on April 7) O.P.+ 2,675 mm (Increase from initial level:3,401 mm, 31 mm decrease since 16:00 on April 7) O.P.+ 4,318 mm (Water level from floor:522 mm, No change since 16:00 on April 7)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 18:43 on April 6)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:16 on March 22)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:23 on April 4 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.