

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on April 9)**

Water Level of the accumulated water (at 7:00 on April 9)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,209 mm (32 mm decrease since 16:00 on April 8)	O.P.+ 2,812 mm (10 mm increase since 16:00 on April 8)	—
	Water level of Turbine Building	O.P.+ 2,774 mm (7 mm increase since 16:00 on April 8)	O.P.+ 3,198 mm (28 mm decrease since 16:00 on April 8)	O.P.+ 2,703 mm (12 mm increase since 16:00 on April 8)	O.P.+ 2,683 mm (11 mm increase since 16:00 on April 8)
	Water level of Reactor Building	O.P.+ 4,630 mm (16 mm decrease since 16:00 on April 8)	O.P.+ 3,505 mm (19 mm decrease since 16:00 on April 8)	O.P.+ 2,911 mm (13 mm increase since 16:00 on April 8)	O.P.+ 2,701 mm (12 mm increase since 16:00 on April 8)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,265 mm (Increase from initial level:5,482 mm, 3 mm increase since 16:00 on April 8) O.P.+ 2,634 mm (Increase from initial level:3,360 mm, 27 mm decrease since 16:00 on April 8) O.P.+ 4,319 mm (Water level from floor:523 mm, 1 mm increase since 16:00 on April 8)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 18:43 on April 6)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:16 on March 22)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:23 on April 4 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.