

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on April 9)**

Water Level of the accumulated water (at 16:00 on April 9)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,192 mm (17 mm decrease since 7:00 on April 9)	O.P.+ 2,818 mm (6 mm increase since 7:00 on April 9)	—
	Water level of Turbine Building	O.P.+ 2,780 mm (6 mm increase since 7:00 on April 9)	O.P.+ 3,183 mm (15 mm decrease since 7:00 on April 9)	O.P.+ 2,709 mm (6 mm increase since 7:00 on April 9)	O.P.+ 2,690 mm (7 mm increase since 7:00 on April 9)
	Water level of Reactor Building	O.P.+ 4,617 mm (13 mm decrease since 7:00 on April 9)	O.P.+ 3,492 mm (13 mm decrease since 7:00 on April 9)	O.P.+ 2,917 mm (6 mm increase since 7:00 on April 9)	O.P.+ 2,708 mm (7 mm increase since 7:00 on April 9)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,266 mm (Increase from initial level:5,483 mm, 1 mm increase since 7:00 on April 9) O.P.+ 2,624 mm (Increase from initial level:3,350 mm, 10 mm decrease since 7:00 on April 9) O.P.+ 4,319 mm (Water level from floor:523 mm, No change since 7:00 on April 9)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 18:43 on April 6)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:16 on March 22)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:23 on April 4   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.