

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on April 10)**

Water Level of the accumulated water (at 7:00 on April 10)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,160 mm (32 mm decrease since 16:00 on April 9)	O.P.+ 2,830 mm (12 mm increase since 16:00 on April 9)	—
	Water level of Turbine Building	O.P.+ 2,786 mm (6 mm increase since 16:00 on April 9)	O.P.+ 3,157 mm (26 mm decrease since 16:00 on April 9)	O.P.+ 2,720 mm (11 mm increase since 16:00 on April 9)	O.P.+ 2,701 mm (11 mm increase since 16:00 on April 9)
	Water level of Reactor Building	O.P.+ 4,593 mm (24 mm decrease since 16:00 on April 9)	O.P.+ 3,465 mm (27 mm decrease since 16:00 on April 9)	O.P.+ 2,932 mm (15 mm increase since 16:00 on April 9)	O.P.+ 2,717 mm (9 mm increase since 16:00 on April 9)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,268 mm (Increase from initial level:5,485 mm, 2 mm increase since 16:00 on April 9) O.P.+ 2,601 mm (Increase from initial level:3,327 mm, 23 mm decrease since 16:00 on April 9) O.P.+ 4,320 mm (Water level from floor:524 mm, 1 mm increase since 16:00 on April 9)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 18:43 on April 6)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:16 on March 22)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:23 on April 4   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.