

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on April 10)**

Water Level of the accumulated water (at 16:00 on April 10)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,143 mm (17 mm decrease since 7:00 on April 10)	O.P.+ 2,835 mm (5 mm increase since 7:00 on April 10)	—
	Water level of Turbine Building	O.P.+ 2,790 mm (4 mm increase since 7:00 on April 10)	O.P.+ 3,142 mm (15 mm decrease since 7:00 on April 10)	O.P.+ 2,728 mm (8 mm increase since 7:00 on April 10)	O.P.+ 2,707 mm (6 mm increase since 7:00 on April 10)
	Water level of Reactor Building	O.P.+ 4,574 mm (19 mm decrease since 7:00 on April 10)	O.P.+ 3,451 mm (14 mm decrease since 7:00 on April 10)	O.P.+ 2,935 mm (3 mm increase since 7:00 on April 10)	O.P.+ 2,723 mm (6 mm increase since 7:00 on April 10)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,270 mm (Increase from initial level:5,487 mm, 2 mm increase since 7:00 on April 10) O.P.+ 2,588 mm (Increase from initial level:3,314 mm, 13 mm decrease since 7:00 on April 10) O.P.+ 4,320 mm (Water level from floor:524 mm, No change since 7:00 on April 10)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 18:43 on April 6)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:16 on March 22)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:23 on April 4 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.