

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on April 11)**

Water Level of the accumulated water (at 7:00 on April 11)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,111 mm (32 mm decrease since 16:00 on April 10)	O.P.+ 2,846 mm (11 mm increase since 16:00 on April 10)	—
	Water level of Turbine Building	O.P.+ 2,797 mm (7 mm increase since 16:00 on April 10)	O.P.+ 3,115 mm (27 mm decrease since 16:00 on April 10)	O.P.+ 2,739 mm (11 mm increase since 16:00 on April 10)	O.P.+ 2,718 mm (11 mm increase since 16:00 on April 10)
	Water level of Reactor Building	O.P.+ 4,547 mm (27 mm decrease since 16:00 on April 10)	O.P.+ 3,425 mm (26 mm decrease since 16:00 on April 10)	O.P.+ 2,949 mm (14 mm increase since 16:00 on April 10)	O.P.+ 2,732 mm (9 mm increase since 16:00 on April 10)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,273 mm (Increase from initial level:5,490 mm, 3 mm increase since 16:00 on April 10) O.P.+ 2,568 mm (Increase from initial level:3,294 mm, 20 mm decrease since 16:00 on April 10) O.P.+ 4,321 mm (Water level from floor:525 mm, 1 mm increase since 16:00 on April 10)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 18:43 on April 6)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:16 on March 22)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:26 on April 11 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- At 8:26 AM on April 11, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning.				

For quick publication of the data of water level, values are provided as reference values.