

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on April 11)**

Water Level of the accumulated water (at 16:00 on April 11)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,093 mm (18 mm decrease since 7:00 on April 11)	O.P.+ 2,852 mm (6 mm increase since 7:00 on April 11)	—
	Water level of Turbine Building	O.P.+ 2,802 mm (5 mm increase since 7:00 on April 11)	O.P.+ 3,100 mm (15 mm decrease since 7:00 on April 11)	O.P.+ 2,747 mm (8 mm increase since 7:00 on April 11)	O.P.+ 2,724 mm (6 mm increase since 7:00 on April 11)
	Water level of Reactor Building	O.P.+ 4,527 mm (20 mm decrease since 7:00 on April 11)	O.P.+ 3,410 mm (15 mm decrease since 7:00 on April 11)	O.P.+ 2,955 mm (6 mm increase since 7:00 on April 11)	O.P.+ 2,738 mm (6 mm increase since 7:00 on April 11)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,274 mm (Increase from initial level:5,491 mm, 1 mm increase since 7:00 on April 11) O.P.+ 2,742 mm (Increase from initial level:3,468 mm, 174 mm increase since 7:00 on April 11) O.P.+ 4,320 mm (Water level from floor:524 mm, 1 mm decrease since 7:00 on April 11)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 18:43 on April 6)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:16 on March 22)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:43 on April 11   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	At 8:26 AM on April 11, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning. At 0:57 PM on the same day, the apparatus was restarted after the filter cleaning, and the steady flow rate was achieved at 1:43 PM on the same day.				

For quick publication of the data of water level, values are provided as reference values.