

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on April 12)**

Water Level of the accumulated water (at 16:00 on April 12)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,085 mm (22 mm increase since 7:00 on April 12)	O.P.+ 2,851 mm (9 mm decrease since 7:00 on April 12)	—
	Water level of Turbine Building	O.P.+ 2,812 mm (5 mm decrease since 7:00 on April 12)	O.P.+ 3,093 mm (19 mm increase since 7:00 on April 12)	O.P.+ 2,737 mm (18 mm decrease since 7:00 on April 12)	O.P.+ 2,738 mm (4 mm increase since 7:00 on April 12)
	Water level of Reactor Building	O.P.+ 4,481 mm (11 mm decrease since 7:00 on April 12)	O.P.+ 3,383 mm (No change since 7:00 on April 12)	O.P.+ 2,953 mm (15 mm decrease since 7:00 on April 12)	O.P.+ 2,752 mm (6 mm increase since 7:00 on April 12)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,278 mm (Increase from initial level:5,495 mm, 1 mm increase since 7:00 on April 12) O.P.+ 2,719 mm (Increase from initial level:3,445 mm, 7 mm decrease since 7:00 on April 12) O.P.+ 4,321 mm (Water level from floor:525 mm, 1 mm increase since 7:00 on April 12)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Transfer Completed (From 18:43 on April 6 to 9:38 on April 12)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:16 on March 22)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:43 on April 11 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.