

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on April 15)**

Water Level of the accumulated water (at 7:00 on April 15)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,288 mm (48 mm increase since 16:00 on April 14)	O.P.+ 2,790 mm (11 mm decrease since 16:00 on April 14)	—
	Water level of Turbine Building	O.P.+ 2,831 mm (5 mm increase since 16:00 on April 14)	O.P.+ 3,266 mm (40 mm increase since 16:00 on April 14)	O.P.+ 2,640 mm (12 mm decrease since 16:00 on April 14)	O.P.+ 2,683 mm (15 mm decrease since 16:00 on April 14)
	Water level of Reactor Building	O.P.+ 4,426 mm (18 mm decrease since 16:00 on April 14)	O.P.+ 3,543 mm (28 mm increase since 16:00 on April 14)	O.P.+ 2,847 mm (17 mm decrease since 16:00 on April 14)	O.P.+ 2,704 mm (15 mm decrease since 16:00 on April 14)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,288 mm (Increase from initial level:5,505 mm, 3 mm increase since 16:00 on April 14) O.P.+ 2,616 mm (Increase from initial level:3,342 mm, 52 mm decrease since 16:00 on April 14) O.P.+ 4,324 mm (Water level from floor:528 mm, 1 mm increase since 16:00 on April 14)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:16 on March 22)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:43 on April 11 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.