

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on April 15)**

Water Level of the accumulated water (at 16:00 on April 15)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,313 mm (25 mm increase since 7:00 on April 15)	O.P.+ 2,781 mm (9 mm decrease since 7:00 on April 15)	—
	Water level of Turbine Building	O.P.+ 2,832 mm (1 mm increase since 7:00 on April 15)	O.P.+ 3,290 mm (24 mm increase since 7:00 on April 15)	O.P.+ 2,631 mm (9 mm decrease since 7:00 on April 15)	O.P.+ 2,673 mm (10 mm decrease since 7:00 on April 15)
	Water level of Reactor Building	O.P.+ 4,413 mm (13 mm decrease since 7:00 on April 15)	O.P.+ 3,569 mm (26 mm increase since 7:00 on April 15)	O.P.+ 2,840 mm (7 mm decrease since 7:00 on April 15)	O.P.+ 2,697 mm (7 mm decrease since 7:00 on April 15)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,290 mm (Increase from initial level:5,507 mm, 2 mm increase since 7:00 on April 15) O.P.+ 2,584 mm (Increase from initial level:3,310 mm, 32 mm decrease since 7:00 on April 15) O.P.+ 4,323 mm (Water level from floor:527 mm, 1 mm decrease since 7:00 on April 15)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:16 on March 22)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:43 on April 11   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.