

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on April 16)**

Water Level of the accumulated water (at 7:00 on April 16)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,355 mm (42 mm increase since 16:00 on April 15)	O.P.+ 2,767 mm (14 mm decrease since 16:00 on April 15)	—
	Water level of Turbine Building	O.P.+ 2,837 mm (5 mm increase since 16:00 on April 15)	O.P.+ 3,326 mm (36 mm increase since 16:00 on April 15)	O.P.+ 2,622 mm (9 mm decrease since 16:00 on April 15)	O.P.+ 2,661 mm (12 mm decrease since 16:00 on April 15)
	Water level of Reactor Building	O.P.+ 4,402 mm (11 mm decrease since 16:00 on April 15)	O.P.+ 3,603 mm (34 mm increase since 16:00 on April 15)	O.P.+ 2,829 mm (11 mm decrease since 16:00 on April 15)	O.P.+ 2,684 mm (13 mm decrease since 16:00 on April 15)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,292 mm (Increase from initial level:5,509 mm, 2 mm increase since 16:00 on April 15) O.P.+ 2,510 mm (Increase from initial level:3,236 mm, 74 mm decrease since 16:00 on April 15) O.P.+ 4,325 mm (Water level from floor:529 mm, 2 mm increase since 16:00 on April 15)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:16 on March 22)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:43 on April 11 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.