

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on April 16)**

Water Level of the accumulated water (at 16:00 on April 16)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,341 mm (14 mm decrease since 7:00 on April 16)	O.P.+ 2,767 mm (No change since 7:00 on April 16)	—
	Water level of Turbine Building	O.P.+ 2,837 mm (No change since 7:00 on April 16)	O.P.+ 3,315 mm (11 mm decrease since 7:00 on April 16)	O.P.+ 2,645 mm (23 mm increase since 7:00 on April 16)	O.P.+ 2,656 mm (5 mm decrease since 7:00 on April 16)
	Water level of Reactor Building	O.P.+ 4,397 mm (5 mm decrease since 7:00 on April 16)	O.P.+ 3,607 mm (4 mm increase since 7:00 on April 16)	O.P.+ 2,848 mm (19 mm increase since 7:00 on April 16)	O.P.+ 2,677 mm (7 mm decrease since 7:00 on April 16)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,293 mm (Increase from initial level:5,510 mm, 1 mm increase since 7:00 on April 16) O.P.+ 2,472 mm (Increase from initial level:3,198 mm, 38 mm decrease since 7:00 on April 16) O.P.+ 4,324 mm (Water level from floor:528 mm, 1 mm decrease since 7:00 on April 16)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:55 on April 16)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:16 on March 22)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:43 on April 11 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.