

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on April 18)**

Water Level of the accumulated water (at 16:00 on April 18)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,224 mm (20 mm decrease since 7:00 on April 18)	O.P.+ 2,807 mm (8 mm increase since 7:00 on April 18)	—
	Water level of Turbine Building	O.P.+ 2,844 mm (1 mm increase since 7:00 on April 18)	O.P.+ 3,214 mm (17 mm decrease since 7:00 on April 18)	O.P.+ 2,697 mm (8 mm increase since 7:00 on April 18)	O.P.+ 2,684 mm (7 mm increase since 7:00 on April 18)
	Water level of Reactor Building	O.P.+ 4,335 mm (16 mm decrease since 7:00 on April 18)	O.P.+ 3,511 mm (14 mm decrease since 7:00 on April 18)	O.P.+ 2,907 mm (7 mm increase since 7:00 on April 18)	O.P.+ 2,700 mm (6 mm increase since 7:00 on April 18)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,302 mm (Increase from initial level:5,519 mm, 3 mm increase since 7:00 on April 18) O.P.+ 2,598 mm (Increase from initial level:3,324 mm, 130 mm increase since 7:00 on April 18) O.P.+ 4,327 mm (Water level from floor:531 mm, 1 mm increase since 7:00 on April 18)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:55 on April 16)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:16 on March 22)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 11:48 on April 18 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	At 8:21 AM on April 18, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning. At 11:19 AM on the same day, the apparatus was restarted after the filter cleaning, and the steady flow rate was achieved at 11:48 AM on the same day.				

For quick publication of the data of water level, values are provided as reference values.