

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on April 19)**

Water Level of the accumulated water (at 7:00 on April 19)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,191 mm (33 mm decrease since 16:00 on April 18)	O.P.+ 2,818 mm (11 mm increase since 16:00 on April 18)	—
	Water level of Turbine Building	O.P.+ 2,845 mm (1 mm increase since 16:00 on April 18)	O.P.+ 3,186 mm (28 mm decrease since 16:00 on April 18)	O.P.+ 2,710 mm (13 mm increase since 16:00 on April 18)	O.P.+ 2,697 mm (13 mm increase since 16:00 on April 18)
	Water level of Reactor Building	O.P.+ 4,312 mm (23 mm decrease since 16:00 on April 18)	O.P.+ 3,483 mm (28 mm decrease since 16:00 on April 18)	O.P.+ 2,923 mm (16 mm increase since 16:00 on April 18)	O.P.+ 2,710 mm (10 mm increase since 16:00 on April 18)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,304 mm (Increase from initial level:5,521 mm, 2 mm increase since 16:00 on April 18) O.P.+ 2,654 mm (Increase from initial level:3,380 mm, 56 mm increase since 16:00 on April 18) O.P.+ 4,327 mm (Water level from floor:531 mm, No change since 16:00 on April 18)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:55 on April 16)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:16 on March 22)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 11:48 on April 18 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.