

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on April 22)**

Water Level of the accumulated water (at 7:00 on April 22)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,042 mm (28 mm decrease since 16:00 on April 21)	O.P.+ 2,884 mm (13 mm increase since 16:00 on April 21)	—
	Water level of Turbine Building	O.P.+ 2,853 mm (2 mm increase since 16:00 on April 21)	O.P.+ 3,059 mm (22 mm decrease since 16:00 on April 21)	O.P.+ 2,777 mm (12 mm increase since 16:00 on April 21)	O.P.+ 2,756 mm (12 mm increase since 16:00 on April 21)
	Water level of Reactor Building	O.P.+ 4,336 mm (25 mm increase since 16:00 on April 21)	O.P.+ 3,360 mm (30 mm decrease since 16:00 on April 21)	O.P.+ 2,994 mm (11 mm increase since 16:00 on April 21)	O.P.+ 2,767 mm (11 mm increase since 16:00 on April 21)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,315 mm (Increase from initial level:5,532 mm, 2 mm increase since 16:00 on April 21) O.P.+ 2,958 mm (Increase from initial level:3,684 mm, 72 mm increase since 16:00 on April 21) O.P.+ 4,326 mm (Water level from floor:530 mm, 1 mm decrease since 16:00 on April 21)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:55 on April 16)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:16 on March 22)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 11:48 on April 18 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.