

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on April 22)**

Water Level of the accumulated water (at 16:00 on April 22)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,026 mm (16 mm decrease since 7:00 on April 22)	O.P.+ 2,892 mm (8 mm increase since 7:00 on April 22)	—
	Water level of Turbine Building	O.P.+ 2,858 mm (5 mm increase since 7:00 on April 22)	O.P.+ 3,044 mm (15 mm decrease since 7:00 on April 22)	O.P.+ 2,785 mm (8 mm increase since 7:00 on April 22)	O.P.+ 2,763 mm (7 mm increase since 7:00 on April 22)
	Water level of Reactor Building	O.P.+ 4,334 mm (2 mm decrease since 7:00 on April 22)	O.P.+ 3,342 mm (18 mm decrease since 7:00 on April 22)	O.P.+ 3,001 mm (7 mm increase since 7:00 on April 22)	O.P.+ 2,774 mm (7 mm increase since 7:00 on April 22)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,316 mm (Increase from initial level:5,533 mm, 1 mm increase since 7:00 on April 22) O.P.+ 3,007 mm (Increase from initial level:3,733 mm, 49 mm increase since 7:00 on April 22) O.P.+ 4,327 mm (Water level from floor:531 mm, 1 mm increase since 7:00 on April 22)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:55 on April 16)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:16 on March 22)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 11:48 on April 18 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.