

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on April 23)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 16:00 on April 23)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,017 mm (20 mm increase since 7:00 on April 23)	O.P.+ 2,905 mm (5 mm increase since 7:00 on April 23)	—
	Water level of Turbine Building	O.P.+ 2,864 mm (3 mm increase since 7:00 on April 23)	O.P.+ 3,036 mm (17 mm increase since 7:00 on April 23)	O.P.+ 2,800 mm (5 mm increase since 7:00 on April 23)	O.P.+ 2,780 mm (5 mm increase since 7:00 on April 23)
	Water level of Reactor Building	O.P.+ 4,303 mm (14 mm decrease since 7:00 on April 23)	O.P.+ 3,319 mm (3 mm increase since 7:00 on April 23)	O.P.+ 3,019 mm (6 mm increase since 7:00 on April 23)	O.P.+ 2,791 mm (8 mm increase since 7:00 on April 23)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,320 mm (Increase from initial level:5,537 mm, 2 mm increase since 7:00 on April 23) O.P.+ 2,966 mm (Increase from initial level:3,692 mm, 124 mm decrease since 7:00 on April 23) O.P.+ 4,327 mm (Water level from floor:531 mm, No change since 7:00 on April 23)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Transfer Completed (From 9:55 on April 16 to 9:58 on April 23)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 14:16 on March 22 to 10:25 on April 23)	—
		Unit 5 and 6 —			
Operation condition of water treatment facility	Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 11:48 on April 18 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance				
Notes					

※ For quick publication of the data of water level, values are provided as reference values.