

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on April 24)**

Water Level of the accumulated water (at 7:00 on April 24)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,073 mm (56 mm increase since 16:00 on April 23)	O.P.+ 2,914 mm (9 mm increase since 16:00 on April 23)	—
	Water level of Turbine Building	O.P.+ 2,867 mm (3 mm increase since 16:00 on April 23)	O.P.+ 3,085 mm (49 mm increase since 16:00 on April 23)	O.P.+ 2,810 mm (10 mm increase since 16:00 on April 23)	O.P.+ 2,791 mm (11 mm increase since 16:00 on April 23)
	Water level of Reactor Building	O.P.+ 4,287 mm (16 mm decrease since 16:00 on April 23)	O.P.+ 3,366 mm (47 mm increase since 16:00 on April 23)	O.P.+ 3,027 mm (8 mm increase since 16:00 on April 23)	O.P.+ 2,800 mm (9 mm increase since 16:00 on April 23)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,322 mm (Increase from initial level:5,539 mm, 2 mm increase since 16:00 on April 23) O.P.+ 2,653 mm (Increase from initial level:3,379 mm, 313 mm decrease since 16:00 on April 23) O.P.+ 4,328 mm (Water level from floor:532 mm, 1 mm increase since 16:00 on April 23)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 11:48 on April 18   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.