

Situation of water level, transfer and treatment of the accumulated water in Fukushima Daiichi Nuclear Power Station (at 9:00 on April 25)

Water Level of the accumulated water (at 7:00 on April 25)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,151 mm (46 mm increase since 16:00 on April 24)	O.P.+ 2,908 mm (12 mm decrease since 16:00 on April 24)	—
	Water level of Turbine Building	O.P.+ 2,874 mm (5 mm increase since 16:00 on April 24)	O.P.+ 3,152 mm (42 mm increase since 16:00 on April 24)	O.P.+ 2,781 mm (35 mm decrease since 16:00 on April 24)	O.P.+ 2,797 mm (No change since 16:00 on April 24)
	Water level of Reactor Building	O.P.+ 4,297 mm (13 mm increase since 16:00 on April 24)	O.P.+ 3,435 mm (42 mm increase since 16:00 on April 24)	O.P.+ 3,004 mm (29 mm decrease since 16:00 on April 24)	O.P.+ 2,807 mm (2 mm increase since 16:00 on April 24)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,326 mm (Increase from initial level:5,543 mm, 2 mm increase since 16:00 on April 24) O.P.+ 2,525 mm (Increase from initial level:3,251 mm, 40 mm increase since 16:00 on April 24) O.P.+ 4,329 mm (Water level from floor:533 mm, 1 mm increase since 16:00 on April 24)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 17:08 on April 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:26 on April 25 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	At 8:26 AM on April 25, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning.				

※ For quick publication of the data of water level, values are provided as reference values.