

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on April 25)**

Water Level of the accumulated water (at 16:00 on April 25)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,178 mm (27 mm increase since 7:00 on April 25)	O.P.+ 2,901 mm (7 mm decrease since 7:00 on April 25)	—
	Water level of Turbine Building	O.P.+ 2,878 mm (4 mm increase since 7:00 on April 25)	O.P.+ 3,176 mm (24 mm increase since 7:00 on April 25)	O.P.+ 2,764 mm (17 mm decrease since 7:00 on April 25)	O.P.+ 2,791 mm (6 mm decrease since 7:00 on April 25)
	Water level of Reactor Building	O.P.+ 4,308 mm (11 mm increase since 7:00 on April 25)	O.P.+ 3,456 mm (21 mm increase since 7:00 on April 25)	O.P.+ 2,987 mm (17 mm decrease since 7:00 on April 25)	O.P.+ 2,802 mm (5 mm decrease since 7:00 on April 25)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,328 mm (Increase from initial level:5,545 mm, 2 mm increase since 7:00 on April 25) O.P.+ 2,699 mm (Increase from initial level:3,425 mm, 174 mm increase since 7:00 on April 25) O.P.+ 4,329 mm (Water level from floor:533 mm, No change since 7:00 on April 25)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 17:08 on April 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:24 on April 25   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.