

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on April 26)**

Water Level of the accumulated water (at 7:00 on April 26)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,219 mm (41 mm increase since 16:00 on April 25)	O.P.+ 2,887 mm (14 mm decrease since 16:00 on April 25)	—
	Water level of Turbine Building	O.P.+ 2,880 mm (2 mm increase since 16:00 on April 25)	O.P.+ 3,208 mm (32 mm increase since 16:00 on April 25)	O.P.+ 2,741 mm (23 mm decrease since 16:00 on April 25)	O.P.+ 2,777 mm (14 mm decrease since 16:00 on April 25)
	Water level of Reactor Building	O.P.+ 4,321 mm (13 mm increase since 16:00 on April 25)	O.P.+ 3,491 mm (35 mm increase since 16:00 on April 25)	O.P.+ 2,962 mm (25 mm decrease since 16:00 on April 25)	O.P.+ 2,792 mm (10 mm decrease since 16:00 on April 25)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,330 mm (Increase from initial level:5,547 mm, 2 mm increase since 16:00 on April 25) O.P.+ 2,690 mm (Increase from initial level:3,416 mm, 9 mm decrease since 16:00 on April 25) O.P.+ 4,329 mm (Water level from floor:533 mm, No change since 16:00 on April 25)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 17:08 on April 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:24 on April 25 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.