

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on April 26)**

Water Level of the accumulated water (at 16:00 on April 26)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,245 mm (26 mm increase since 7:00 on April 26)	O.P.+ 2,878 mm (9 mm decrease since 7:00 on April 26)	—
	Water level of Turbine Building	O.P.+ 2,883 mm (3 mm increase since 7:00 on April 26)	O.P.+ 3,235 mm (27 mm increase since 7:00 on April 26)	O.P.+ 2,731 mm (10 mm decrease since 7:00 on April 26)	O.P.+ 2,770 mm (7 mm decrease since 7:00 on April 26)
	Water level of Reactor Building	O.P.+ 4,335 mm (14 mm increase since 7:00 on April 26)	O.P.+ 3,519 mm (28 mm increase since 7:00 on April 26)	O.P.+ 2,951 mm (11 mm decrease since 7:00 on April 26)	O.P.+ 2,785 mm (7 mm decrease since 7:00 on April 26)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,332 mm (Increase from initial level:5,549 mm, 2 mm increase since 7:00 on April 26) O.P.+ 2,686 mm (Increase from initial level:3,412 mm, 4 mm decrease since 7:00 on April 26) O.P.+ 4,330 mm (Water level from floor:534 mm, 1 mm increase since 7:00 on April 26)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 17:08 on April 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:24 on April 25   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.