

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on April 30)**

Water Level of the accumulated water (at 7:00 on April 30)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,129 mm (32 mm decrease since 16:00 on April 29)	O.P.+ 2,920 mm (11 mm increase since 16:00 on April 29)	—
	Water level of Turbine Building	O.P.+ 2,923 mm (8 mm increase since 16:00 on April 29)	O.P.+ 3,135 mm (28 mm decrease since 16:00 on April 29)	O.P.+ 2,811 mm (12 mm increase since 16:00 on April 29)	O.P.+ 2,791 mm (12 mm increase since 16:00 on April 29)
	Water level of Reactor Building	O.P.+ 4,414 mm (25 mm decrease since 16:00 on April 29)	O.P.+ 3,436 mm (27 mm decrease since 16:00 on April 29)	O.P.+ 3,032 mm (13 mm increase since 16:00 on April 29)	O.P.+ 2,800 mm (11 mm increase since 16:00 on April 29)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,345 mm (Increase from initial level:5,562 mm, 2 mm increase since 16:00 on April 29) O.P.+ 2,663 mm (Increase from initial level:3,389 mm, 1 mm decrease since 16:00 on April 29) O.P.+ 4,333 mm (Water level from floor:537 mm, 1 mm increase since 16:00 on April 29)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:34 on April 27)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 17:08 on April 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:24 on April 25 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.