

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 1)**

Water Level of the accumulated water (at 7:00 on May 1)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,081 mm (30 mm decrease since 16:00 on April 30)	O.P.+ 2,940 mm (12 mm increase since 16:00 on April 30)	—
	Water level of Turbine Building	O.P.+ 2,932 mm (7 mm increase since 16:00 on April 30)	O.P.+ 3,094 mm (25 mm decrease since 16:00 on April 30)	O.P.+ 2,831 mm (11 mm increase since 16:00 on April 30)	O.P.+ 2,809 mm (12 mm increase since 16:00 on April 30)
	Water level of Reactor Building	O.P.+ 4,371 mm (26 mm decrease since 16:00 on April 30)	O.P.+ 3,398 mm (25 mm decrease since 16:00 on April 30)	O.P.+ 3,051 mm (12 mm increase since 16:00 on April 30)	O.P.+ 2,816 mm (9 mm increase since 16:00 on April 30)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,350 mm (Increase from initial level:5,567 mm, 5 mm increase since 16:00 on April 30) O.P.+ 2,666 mm (Increase from initial level:3,392 mm, 3 mm increase since 16:00 on April 30) O.P.+ 4,333 mm (Water level from floor:537 mm, No change since 16:00 on April 30)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:34 on April 27)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 17:08 on April 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:24 on April 25   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.