

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on May 1)**

Water Level of the accumulated water (at 16:00 on May 1)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,061 mm (20 mm decrease since 7:00 on May 1)	O.P.+ 2,946 mm (6 mm increase since 7:00 on May 1)	—
	Water level of Turbine Building	O.P.+ 2,935 mm (3 mm increase since 7:00 on May 1)	O.P.+ 3,076 mm (18 mm decrease since 7:00 on May 1)	O.P.+ 2,838 mm (7 mm increase since 7:00 on May 1)	O.P.+ 2,816 mm (7 mm increase since 7:00 on May 1)
	Water level of Reactor Building	O.P.+ 4,356 mm (15 mm decrease since 7:00 on May 1)	O.P.+ 3,384 mm (14 mm decrease since 7:00 on May 1)	O.P.+ 3,058 mm (7 mm increase since 7:00 on May 1)	O.P.+ 2,823 mm (7 mm increase since 7:00 on May 1)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,352 mm (Increase from initial level:5,569 mm, 2 mm increase since 7:00 on May 1) O.P.+ 2,669 mm (Increase from initial level:3,395 mm, 3 mm increase since 7:00 on May 1) O.P.+ 4,333 mm (Water level from floor:537 mm, No change since 7:00 on May 1)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:34 on April 27)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 17:08 on April 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:24 on April 25 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.