

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 2)**

| | | | | | |
|--|---|--|--|--|---|
| Water Level of the accumulated water (at 7:00 on May 2) | | Unit 1 | Unit 2 | Unit 3 | Unit 4 |
| | Water level of Vertical Shaft | Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm) | O.P.+ 3,030 mm (31 mm decrease since 16:00 on May 1) | O.P.+ 2,956 mm (10 mm increase since 16:00 on May 1) | — |
| | Water level of Turbine Building | O.P.+ 2,942 mm (7 mm increase since 16:00 on May 1) | O.P.+ 3,050 mm (26 mm decrease since 16:00 on May 1) | O.P.+ 2,851 mm (13 mm increase since 16:00 on May 1) | O.P.+ 2,826 mm (10 mm increase since 16:00 on May 1) |
| | Water level of Reactor Building | O.P.+ 4,333 mm (23 mm decrease since 16:00 on May 1) | O.P.+ 3,353 mm (31 mm decrease since 16:00 on May 1) | O.P.+ 3,067 mm (9 mm increase since 16:00 on May 1) | O.P.+ 2,833 mm (10 mm increase since 16:00 on May 1) |
| | Water level of each building in the Centralized Radiation Waste Treatment Facility | Process Main Building High Temperature Incinerator Building On-site Bunker Building | O.P.+ 4,354 mm (Increase from initial level:5,571 mm, 2 mm increase since 16:00 on May 1) O.P.+ 2,671 mm (Increase from initial level:3,397 mm, 2 mm increase since 16:00 on May 1) O.P.+ 4,334 mm (Water level from floor:538 mm, 1 mm increase since 16:00 on May 1) | | |
| Situation of transfer of the accumulated water | | Unit 1 | Unit 2 | Unit 3 | Unit 4 |
| | | — | Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:34 on April 27) | Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 17:08 on April 24) | — |
| | | Unit 5 and 6 | | | |
| | | — | | | |
| Operation condition of water treatment facility | | Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:28 on May 2 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance | | | |
| Notes | – At 8:28 AM on May 2, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning. | | | | |

※ For quick publication of the data of water level, values are provided as reference values.