

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on May 7)**

Water Level of the accumulated water (at 16:00 on May 7)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,253 mm (13 mm decrease since 7:00 on May 7)	O.P.+ 2,869 mm (4 mm decrease since 7:00 on May 7)	—
	Water level of Turbine Building	O.P.+ 2,738 mm (3 mm increase since 7:00 on May 7)	O.P.+ 3,242 mm (11 mm decrease since 7:00 on May 7)	O.P.+ 2,734 mm (18 mm increase since 7:00 on May 7)	O.P.+ 2,757 mm (9 mm decrease since 7:00 on May 7)
	Water level of Reactor Building	O.P.+ 4,341 mm (6 mm increase since 7:00 on May 7)	O.P.+ 3,540 mm (No change since 7:00 on May 7)	O.P.+ 2,945 mm (13 mm increase since 7:00 on May 7)	O.P.+ 2,774 mm (8 mm decrease since 7:00 on May 7)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,375 mm (Increase from initial level:5,592 mm, 2 mm increase since 7:00 on May 7) O.P.+ 2,734 mm (Increase from initial level:3,460 mm, 8 mm increase since 7:00 on May 7) O.P.+ 4,338 mm (Water level from floor:542 mm, 1 mm increase since 7:00 on May 7)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:50 on May 7)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 17:08 on April 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:10 on May 2 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.