

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on May 8)**

Water Level of the accumulated water (at 16:00 on May 8)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,184 mm (24 mm decrease since 7:00 on May 8)	O.P.+ 2,888 mm (8 mm increase since 7:00 on May 8)	—
	Water level of Turbine Building	O.P.+ 2,741 mm (2 mm increase since 7:00 on May 8)	O.P.+ 3,180 mm (24 mm decrease since 7:00 on May 8)	O.P.+ 2,774 mm (9 mm increase since 7:00 on May 8)	O.P.+ 2,760 mm (5 mm increase since 7:00 on May 8)
	Water level of Reactor Building	O.P.+ 4,336 mm (3 mm decrease since 7:00 on May 8)	O.P.+ 3,487 mm (19 mm decrease since 7:00 on May 8)	O.P.+ 2,990 mm (10 mm increase since 7:00 on May 8)	O.P.+ 2,773 mm (4 mm increase since 7:00 on May 8)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,378 mm (Increase from initial level:5,595 mm, 1 mm increase since 7:00 on May 8) O.P.+ 2,726 mm (Increase from initial level:3,452 mm, 3 mm decrease since 7:00 on May 8) O.P.+ 4,337 mm (Water level from floor:541 mm, No change since 7:00 on May 8)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:50 on May 7)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 17:08 on April 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:10 on May 2   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.