

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 9)**

Water Level of the accumulated water (at 7:00 on May 9)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,143 mm (41 mm decrease since 16:00 on May 8)	O.P.+ 2,899 mm (11 mm increase since 16:00 on May 8)	—
	Water level of Turbine Building	O.P.+ 2,743 mm (2 mm increase since 16:00 on May 8)	O.P.+ 3,148 mm (32 mm decrease since 16:00 on May 8)	O.P.+ 2,787 mm (13 mm increase since 16:00 on May 8)	O.P.+ 2,769 mm (9 mm increase since 16:00 on May 8)
	Water level of Reactor Building	O.P.+ 4,329 mm (7 mm decrease since 16:00 on May 8)	O.P.+ 3,454 mm (33 mm decrease since 16:00 on May 8)	O.P.+ 3,003 mm (13 mm increase since 16:00 on May 8)	O.P.+ 2,780 mm (7 mm increase since 16:00 on May 8)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,381 mm (Increase from initial level:5,598 mm, 3 mm increase since 16:00 on May 8) O.P.+ 2,722 mm (Increase from initial level:3,448 mm, 4 mm decrease since 16:00 on May 8) O.P.+ 4,338 mm (Water level from floor:542 mm, 1 mm increase since 16:00 on May 8)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:50 on May 7)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 17:08 on April 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:23 on May 9 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- At 8:23 AM on May 9, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning.				

※ For quick publication of the data of water level, values are provided as reference values.