

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on May 9)**

Water Level of the accumulated water (at 16:00 on May 9)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,121 mm (22 mm decrease since 7:00 on May 9)	O.P.+ 2,906 mm (7 mm increase since 7:00 on May 9)	—
	Water level of Turbine Building	O.P.+ 2,743 mm (No change since 7:00 on May 9)	O.P.+ 3,128 mm (20 mm decrease since 7:00 on May 9)	O.P.+ 2,795 mm (8 mm increase since 7:00 on May 9)	O.P.+ 2,775 mm (6 mm increase since 7:00 on May 9)
	Water level of Reactor Building	O.P.+ 4,322 mm (7 mm decrease since 7:00 on May 9)	O.P.+ 3,436 mm (18 mm decrease since 7:00 on May 9)	O.P.+ 3,013 mm (10 mm increase since 7:00 on May 9)	O.P.+ 2,786 mm (6 mm increase since 7:00 on May 9)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,382 mm (Increase from initial level:5,599 mm, 1 mm increase since 7:00 on May 9) O.P.+ 2,884 mm (Increase from initial level:3,610 mm, 162 mm increase since 7:00 on May 9) O.P.+ 4,339 mm (Water level from floor:543 mm, 1 mm increase since 7:00 on May 9)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:50 on May 7)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 17:08 on April 24)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:10 on May 9 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* We stopped the Second Cesium Absorption Apparatus (SARRY) at 8:23 on May 9 due to a filter cleaning. After we finished it, we restarted SARRY 12:12 on the same day, and confirmed the normal flow at 13:10.				

For quick publication of the data of water level, values are provided as reference values.