

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on May 10)**

| | | | | | |
|--|--|--|--|--|--|
| Water Level of the accumulated water (at 16:00 on May 10) | | Unit 1 | Unit 2 | Unit 3 | Unit 4 |
| | Water level of Vertical Shaft | Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm) | O.P.+ 3,062 mm (22 mm decrease since 7:00 on May 10) | O.P.+ 2,925 mm (8 mm increase since 7:00 on May 10) | — |
| | Water level of Turbine Building | O.P.+ 2,747 mm (3 mm increase since 7:00 on May 10) | O.P.+ 3,076 mm (20 mm decrease since 7:00 on May 10) | O.P.+ 2,813 mm (6 mm increase since 7:00 on May 10) | O.P.+ 2,791 mm (7 mm increase since 7:00 on May 10) |
| | Water level of Reactor Building | O.P.+ 4,306 mm (8 mm decrease since 7:00 on May 10) | O.P.+ 3,387 mm (20 mm decrease since 7:00 on May 10) | O.P.+ 3,033 mm (7 mm increase since 7:00 on May 10) | O.P.+ 2,799 mm (5 mm increase since 7:00 on May 10) |
| | Water level of each building in the Centralized Radiation Waste Treatment Facility | Process Main Building High Temperature Incinerator Building On-site Bunker Building | O.P.+ 4,386 mm (Increase from initial level:5,603 mm, 1 mm increase since 7:00 on May 10) O.P.+ 2,861 mm (Increase from initial level:3,587 mm, 9 mm decrease since 7:00 on May 10) O.P.+ 4,339 mm (Water level from floor:543 mm, No change since 7:00 on May 10) | | |
| Situation of transfer of the accumulated water | | Unit 1 | Unit 2 | Unit 3 | Unit 4 |
| | | — | Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:50 on May 7) | Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 17:08 on April 24) | — |
| | | Unit 5 and 6 | | | |
| | | — | | | |
| Operation condition of water treatment facility | | Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:10 on May 9 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance | | | |
| Notes | | | | | |

※ For quick publication of the data of water level, values are provided as reference values.