

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 13)**

Water Level of the accumulated water (at 7:00 on May 13)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,920 mm (33 mm decrease since 16:00 on May 12)	O.P.+ 2,968 mm (10 mm increase since 16:00 on May 12)	—
	Water level of Turbine Building	O.P.+ 2,747 mm (No change since 16:00 on May 12)	O.P.+ 2,957 mm (28 mm decrease since 16:00 on May 12)	O.P.+ 2,861 mm (12 mm increase since 16:00 on May 12)	O.P.+ 2,835 mm (11 mm increase since 16:00 on May 12)
	Water level of Reactor Building	O.P.+ 4,260 mm (17 mm decrease since 16:00 on May 12)	O.P.+ 3,265 mm (33 mm decrease since 16:00 on May 12)	O.P.+ 3,084 mm (10 mm increase since 16:00 on May 12)	O.P.+ 2,840 mm (10 mm increase since 16:00 on May 12)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,397 mm (Increase from initial level:5,614 mm, 2 mm increase since 16:00 on May 12) O.P.+ 2,820 mm (Increase from initial level:3,546 mm, 8 mm decrease since 16:00 on May 12) O.P.+ 4,341 mm (Water level from floor:545 mm, No change since 16:00 on May 12)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:50 on May 7)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 17:08 on April 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:10 on May 9   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.