

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on May 13)**

Water Level of the accumulated water (at 16:00 on May 13)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,940 mm (20 mm increase since 7:00 on May 13)	O.P.+ 2,971 mm (3 mm increase since 7:00 on May 13)	—
	Water level of Turbine Building	O.P.+ 2,752 mm (5 mm increase since 7:00 on May 13)	O.P.+ 2,975 mm (18 mm increase since 7:00 on May 13)	O.P.+ 2,867 mm (6 mm increase since 7:00 on May 13)	O.P.+ 2,841 mm (6 mm increase since 7:00 on May 13)
	Water level of Reactor Building	O.P.+ 4,242 mm (18 mm decrease since 7:00 on May 13)	O.P.+ 3,266 mm (1 mm increase since 7:00 on May 13)	O.P.+ 3,089 mm (5 mm increase since 7:00 on May 13)	O.P.+ 2,846 mm (6 mm increase since 7:00 on May 13)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,399 mm (Increase from initial level:5,616 mm, 2 mm increase since 7:00 on May 13) O.P.+ 2,667 mm (Increase from initial level:3,393 mm, 153 mm decrease since 7:00 on May 13) O.P.+ 4,342 mm (Water level from floor:546 mm, 1 mm increase since 7:00 on May 13)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Transfer Completed (From 9:50 on May 7 to 9:24 on May 13)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 17:08 on April 24 to 9:47 on May 13)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:10 on May 9 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.