

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 14)**

Water Level of the accumulated water (at 7:00 on May 14)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,991 mm (51 mm increase since 16:00 on May 13)	O.P.+ 2,981 mm (10 mm increase since 16:00 on May 13)	—
	Water level of Turbine Building	O.P.+ 2,750 mm (2 mm decrease since 16:00 on May 13)	O.P.+ 3,017 mm (42 mm increase since 16:00 on May 13)	O.P.+ 2,876 mm (9 mm increase since 16:00 on May 13)	O.P.+ 2,850 mm (9 mm increase since 16:00 on May 13)
	Water level of Reactor Building	O.P.+ 4,224 mm (18 mm decrease since 16:00 on May 13)	O.P.+ 3,308 mm (42 mm increase since 16:00 on May 13)	O.P.+ 3,099 mm (10 mm increase since 16:00 on May 13)	O.P.+ 2,855 mm (9 mm increase since 16:00 on May 13)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,401 mm (Increase from initial level:5,618 mm, 2 mm increase since 16:00 on May 13) O.P.+ 2,307 mm (Increase from initial level:3,033 mm, 360 mm decrease since 16:00 on May 13) O.P.+ 4,342 mm (Water level from floor:546 mm, No change since 16:00 on May 13)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:10 on May 9 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.