

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on May 14)**

Water Level of the accumulated water (at 16:00 on May 14)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,021 mm (30 mm increase since 7:00 on May 14)	O.P.+ 2,986 mm (5 mm increase since 7:00 on May 14)	—
	Water level of Turbine Building	O.P.+ 2,753 mm (3 mm increase since 7:00 on May 14)	O.P.+ 3,044 mm (27 mm increase since 7:00 on May 14)	O.P.+ 2,883 mm (7 mm increase since 7:00 on May 14)	O.P.+ 2,856 mm (6 mm increase since 7:00 on May 14)
	Water level of Reactor Building	O.P.+ 4,218 mm (6 mm decrease since 7:00 on May 14)	O.P.+ 3,334 mm (26 mm increase since 7:00 on May 14)	O.P.+ 3,107 mm (8 mm increase since 7:00 on May 14)	O.P.+ 2,860 mm (5 mm increase since 7:00 on May 14)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,402 mm (Increase from initial level:5,619 mm, 1 mm increase since 7:00 on May 14) O.P.+ 2,095 mm (Increase from initial level:2,821 mm, 212 mm decrease since 7:00 on May 14) O.P.+ 4,343 mm (Water level from floor:547 mm, 1 mm increase since 7:00 on May 14)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:10 on May 9 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.