

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 15)**

Water Level of the accumulated water (at 7:00 on May 15)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,062 mm (41 mm increase since 16:00 on May 14)	O.P.+ 2,996 mm (10 mm increase since 16:00 on May 14)	—
	Water level of Turbine Building	O.P.+ 2,755 mm (2 mm increase since 16:00 on May 14)	O.P.+ 3,076 mm (32 mm increase since 16:00 on May 14)	O.P.+ 2,893 mm (10 mm increase since 16:00 on May 14)	O.P.+ 2,864 mm (8 mm increase since 16:00 on May 14)
	Water level of Reactor Building	O.P.+ 4,214 mm (4 mm decrease since 16:00 on May 14)	O.P.+ 3,374 mm (40 mm increase since 16:00 on May 14)	O.P.+ 3,117 mm (10 mm increase since 16:00 on May 14)	O.P.+ 2,869 mm (9 mm increase since 16:00 on May 14)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,405 mm (Increase from initial level:5,622 mm, 3 mm increase since 16:00 on May 14) O.P.+ 1,746 mm (Increase from initial level:2,472 mm, 349 mm decrease since 16:00 on May 14) O.P.+ 4,343 mm (Water level from floor:547 mm, No change since 16:00 on May 14)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:10 on May 9   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.