## Situation of water level, transfer and treatment of the accumulated water in Fukushima Daiichi Nuclear Power Station (at 18:00 on May 15)

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 16:00 on May 15)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,087 mm (25 mm increase since 7:00 on May 15)	O.P.+ 3,001 mm (5 mm increase since 7:00 on May 15)	_
	Water level of Turbine Building	O.P.+ 2,754 mm (1 mm decrease since 7:00 on May 15)	O.P.+ 3,100 mm (24 mm increase since 7:00 on May 15)	O.P.+ 2,899 mm (6 mm increase since 7:00 on May 15)	O.P.+ 2,871 mm (7 mm increase since 7:00 on May 15)
	Water level of Reactor Building	O.P.+ 4,217 mm (3 mm increase since 7:00 on May 15)	O.P.+ 3,397 mm (23 mm increase since 7:00 on May 15)	O.P.+ 3,124 mm (7 mm increase since 7:00 on May 15)	O.P.+ 2,875 mm (6 mm increase since 7:00 on May 15)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building	O.P.+ 4,407 mm (Increase from initial level:5,624 mm, 2 mm increase since 7:00 on May 15)		
		High Temperature Incinerator Building	O.P.+ 1,538 mm (Increase from initial level:2,264 mm, 208 mm decrease since 7:00 on May 15)		
		On-site Bunker Building	O.P.+ 4,343 mm (Water level from floor:547 mm, No change since 7:00 on May 15)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		_	_	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 17:20 on May 15)	_
		Unit 5 and 6			
		_			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:10 on May 9 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

% For quick publication of the data of water level, values are provided as reference values.