

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 16)**

Water Level of the accumulated water (at 7:00 on May 16)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,130 mm (43 mm increase since 16:00 on May 15)	O.P.+ 2,990 mm (11 mm decrease since 16:00 on May 15)	—
	Water level of Turbine Building	O.P.+ 2,753 mm (1 mm decrease since 16:00 on May 15)	O.P.+ 3,136 mm (36 mm increase since 16:00 on May 15)	O.P.+ 2,863 mm (36 mm decrease since 16:00 on May 15)	O.P.+ 2,873 mm (2 mm increase since 16:00 on May 15)
	Water level of Reactor Building	O.P.+ 4,276 mm (59 mm increase since 16:00 on May 15)	O.P.+ 3,440 mm (43 mm increase since 16:00 on May 15)	O.P.+ 3,103 mm (21 mm decrease since 16:00 on May 15)	O.P.+ 2,883 mm (8 mm increase since 16:00 on May 15)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,410 mm (Increase from initial level:5,627 mm, 3 mm increase since 16:00 on May 15) O.P.+ 1,515 mm (Increase from initial level:2,241 mm, 23 mm decrease since 16:00 on May 15) O.P.+ 4,345 mm (Water level from floor:549 mm, 2 mm increase since 16:00 on May 15)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 17:20 on May 15)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:24 on May 16   Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	At 8:24 AM on May 16, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning.				

※ For quick publication of the data of water level, values are provided as reference values.