

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on May 16)**

Water Level of the accumulated water (at 16:00 on May 16)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,157 mm (27 mm increase since 7:00 on May 16)	O.P.+ 2,983 mm (7 mm decrease since 7:00 on May 16)	—
	Water level of Turbine Building	O.P.+ 2,758 mm (5 mm increase since 7:00 on May 16)	O.P.+ 3,159 mm (23 mm increase since 7:00 on May 16)	O.P.+ 2,846 mm (17 mm decrease since 7:00 on May 16)	O.P.+ 2,868 mm (5 mm decrease since 7:00 on May 16)
	Water level of Reactor Building	O.P.+ 4,313 mm (37 mm increase since 7:00 on May 16)	O.P.+ 3,460 mm (20 mm increase since 7:00 on May 16)	O.P.+ 3,081 mm (22 mm decrease since 7:00 on May 16)	O.P.+ 2,877 mm (6 mm decrease since 7:00 on May 16)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,410 mm (Increase from initial level:5,627 mm, No change since 7:00 on May 16) O.P.+ 1,616 mm (Increase from initial level:2,342 mm, 101 mm increase since 7:00 on May 16) O.P.+ 4,345 mm (Water level from floor:549 mm, No change since 7:00 on May 16)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 17:20 on May 15)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:08 on May 16   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* At 8:24 on May 16, we stopped the 2nd Cesium Absorption Apparatus (SARRY) for filter cleaning. After we completed the cleaning, we started SARRY at 11:08 on the same day and confirmed normal flow.				

※ For quick publication of the data of water level, values are provided as reference values.