

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 20)**

Water Level of the accumulated water (at 7:00 on May 20)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,150 mm (35 mm decrease since 16:00 on May 19)	O.P.+ 2,972 mm (12 mm increase since 16:00 on May 19)	—
	Water level of Turbine Building	O.P.+ 2,767 mm (2 mm increase since 16:00 on May 19)	O.P.+ 3,160 mm (29 mm decrease since 16:00 on May 19)	O.P.+ 2,858 mm (13 mm increase since 16:00 on May 19)	O.P.+ 2,839 mm (11 mm increase since 16:00 on May 19)
	Water level of Reactor Building	O.P.+ 4,345 mm (19 mm decrease since 16:00 on May 19)	O.P.+ 3,463 mm (28 mm decrease since 16:00 on May 19)	O.P.+ 3,082 mm (14 mm increase since 16:00 on May 19)	O.P.+ 2,847 mm (9 mm increase since 16:00 on May 19)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,426 mm (Increase from initial level:5,643 mm, 3 mm increase since 16:00 on May 19) O.P.+ 1,584 mm (Increase from initial level:2,310 mm, 4 mm increase since 16:00 on May 19) O.P.+ 4,346 mm (Water level from floor:550 mm, No change since 16:00 on May 19)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:10 on May 18)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 17:20 on May 15)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:08 on May 16 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.