

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 21)**

Water Level of the accumulated water (at 7:00 on May 21)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,097 mm (33 mm decrease since 16:00 on May 20)	O.P.+ 2,989 mm (12 mm increase since 16:00 on May 20)	—
	Water level of Turbine Building	O.P.+ 2,771 mm (3 mm increase since 16:00 on May 20)	O.P.+ 3,115 mm (29 mm decrease since 16:00 on May 20)	O.P.+ 2,877 mm (12 mm increase since 16:00 on May 20)	O.P.+ 2,855 mm (10 mm increase since 16:00 on May 20)
	Water level of Reactor Building	O.P.+ 4,310 mm (22 mm decrease since 16:00 on May 20)	O.P.+ 3,419 mm (31 mm decrease since 16:00 on May 20)	O.P.+ 3,103 mm (14 mm increase since 16:00 on May 20)	O.P.+ 2,860 mm (9 mm increase since 16:00 on May 20)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,429 mm (Increase from initial level:5,646 mm, 2 mm increase since 16:00 on May 20) O.P.+ 1,598 mm (Increase from initial level:2,324 mm, 9 mm increase since 16:00 on May 20) O.P.+ 4,347 mm (Water level from floor:551 mm, 1 mm decrease since 16:00 on May 20)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:10 on May 18)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 17:20 on May 15)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:08 on May 16 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.